

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

55.0

59.0

9.9

0.3

11.6

9.0

N/A

Intersection ID: 12692 Main Street: WILKINSON_BV Cross Street: SUTTLE_AV Location: NW

ADA ID: E141A2D99C62 Ramp Type: Combination1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 46.25

Compliance Description

Ramp Length LT (in)

Ramp Width LT (in)

Ramp Slope LT (%)

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Landing Width (in)

Landing Slope (%)

Landing X Slope (%)

Landing Curb? (Y/N)

Shared Landing?

Gutter Ponding?

Gutter Lip Ht (in)

Painted X Walk1?

X Walk 1 Direction

X Walk 1 Width (in)

X Walk 1 Slope (%)

X Walk 1 X Slope (%)

Ramp inside XWalk1?

Road Slope (%)

Road X Slope (%)

Flare Traversable LT?

Flare Type LT

Ramp XSlope LT (%)

N/A

Yes

No

Yes

N/A

No

N/A

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

N/A

Yes

No

Yes

Nο

No

N/A

Compliance Description

Ramp Length RT (in)

Ramp Width RT (in)

Ramp Slope RT (%)

Ramp XSlope RT (%)

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

DWS Contrast?

DWS Length (in)

DWS Full Width?

DWS Offset (in)

Gutter Slope (%)

Gutter X Slope (%)

Painted X Walk2?

X Walk 2 Direction

X Walk 2 Width (in)

X Walk 2 Slope (%)

X Walk 2 X Slope (%)

Ramp inside XWalk2?

Clear Space?

Flare Traversable RT?

Data

61.5

59.0

10.8

0.2

50.0

40.0

N/A

No

N/A

7.3

6.6

N/A

N/A

N/A

To SE



Street 1 Name StopSign
Stop Condition-Street 1 SUTTLE AV
Street 2 Name N/A
Stop Condition-Street 2 N/A

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.2.2, R304.5.3, R304.3.2





Total Cost:



1800.00

N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstruction?	N/A
	Obstruction Type	
		N/A
N/A	Storm Grate/Utility Hazard?	N/A
	Storm Grate/Utility Type	
		N/A
Yes	Surface Condition? (G/P)	Good
	Curb Slope (%)	7.6