


# Access Compliance Report

## Public Rights-of-Way (Curb Ramps)

Intersection ID: N/A	Main Street: OLD_PINEVILLE_RD	Cross Street: N/A	Location: NE
ADA ID: E3B28162B60D	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:			
	Remove & Replace Entire Ramp.			
	Surveyor Notes:			
	N/A			
	PROW/ADA:			
	R304.5.3			
	Street 1 Name	ENTRANCE		
	Stop Condition-Street 1	StopSign		
	Street 2 Name	N/A		
	Stop Condition-Street 2	N/A		
Total Cost:		\$	1600.00	
		Compliance	Description	Data
		N/A	Ramp Length (in)	105.0
		Yes	Ramp Width (in)	95.5
		Yes	Ramp Slope (%)	4.9
		No	Ramp XSlope (%)	4.9
		N/A	Flare Type LT	N/A
		N/A	Flare Slope LT (%)	N/A
		N/A	Flare Traversable LT?	N/A
		N/A	Landing Length (in)	0.0
		N/A	Landing Width (in)	0.0
		N/A	Landing Slope (%)	0.0
		N/A	Landing X Slope (%)	0.0
		N/A	Landing Curb? (Y/N)	N/A
		N/A	Shared Landing?	N/A
		N/A	Gutter Ponding?	0.0
		N/A	Gutter Lip Ht (in)	0.0
		N/A	Painted X Walk1?	No
			X Walk 1 Direction	To S
			X Walk 1 Width (in)	N/A
			X Walk 1 Slope (%)	3.1
			X Walk 1 X Slope (%)	5.8
		N/A	Ramp inside XWalk1?	N/A
		N/A	Any Obstructions?	N/A
			Obstruction Type	
		Yes	Surface Condition? (G/P)	Good
		N/A	Curb Slope (%)	7.3

