


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: N/A	Main Street: INDEPENDENCE_RD	Cross Street: N/A	Location: E
ADA ID: EBB542974BA4	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 37.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	76.0	No
			Yes	Ramp Width (in)	50.0	No
			N/A	Flare Type LT	N/A	N/A
			N/A	Flare Slope LT (%)	N/A	N/A
			N/A	Flare Traversable LT?	N/A	N/A
			N/A	Landing Length (in)	N/A	N/A
			N/A	Landing Width (in)	N/A	N/A
			N/A	Landing Slope (%)	N/A	N/A
			N/A	Landing X Slope (%)	N/A	N/A
			N/A	Landing Curb? (Y/N)	N/A	N/A
			N/A	Shared Landing?	N/A	
			N/A	Gutter Ponding?	N/A	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A
			N/A	Painted X Walk1?	No	N/A
				X Walk 1 Direction	To NW	To SW
			N/A	X Walk 1 Width (in)	N/A	N/A
				X Walk 1 Slope (%)	4.2	X Walk 2 Slope (%)
				X Walk 1 X Slope (%)	4.2	X Walk 2 X Slope (%)
			N/A	Ramp inside XWalk1?	N/A	N/A
Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2, R304.5.3				Road Slope (%)	6.9	N/A
				Road X Slope (%)	1.6	N/A
Total Cost:		\$ 3200.00	N/A	Any Obstructions?	N/A	N/A
				Obstruction Type		
					N/A	N/A
					Yes	Surface Condition? (G/P) Good

