


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10034403	Main Street: PIEDMONT_ROW_DR_SOUTH	Cross Street: N/A	Location: SE
ADA ID: EBD3863FEEFD	Ramp Type: ParaDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 13.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length LT (in)	40.0
			Yes	Ramp Width LT (in)	82.0
			No	Ramp Slope LT (%)	8.5
			No	Ramp XSlope LT (%)	3.0
			Yes	Ramp XSlope RT (%)	0.2
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
Surveyor Notes: N/A			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	No
			To N	X Walk 1 Direction	To W
			N/A	X Walk 1 Width (in)	N/A
			4.6	X Walk 1 Slope (%)	7.9
			4.1	X Walk 1 X Slope (%)	4.6
PROW/ADA: R304.3.2, R304.5.3			N/A	Ramp inside XWalk1?	N/A
			2.1	Road Slope (%)	N/A
			8.6	Road X Slope (%)	N/A
			N/A	Any Obstructions?	N/A
				Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	7.9
Total Cost:		\$ 3200.00			

