

Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 7380	Main Street: REAGAN_DR	Cross Street: W_SUGAR_CREEK_RD	Location: SE
ADA ID: EC6CA832A074	Ramp Type: ParaDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

R304.3.2

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	62.5	N/A	Ramp Length RT (in)	62.5
Yes	Ramp Width LT (in)	60.0	Yes	Ramp Width RT (in)	59.0
No	Ramp Slope LT (%)	8.6	No	Ramp Slope RT (%)	9.5
Yes	Ramp XSlope LT (%)	1.7	Yes	Ramp XSlope RT (%)	1.1
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To N		X Walk 2 Direction	To W
N/A	X Walk 1 Width (in)	114.0	N/A	X Walk 2 Width (in)	110.0
	X Walk 1 Slope (%)	0.3		X Walk 2 Slope (%)	0.4
	X Walk 1 X Slope (%)	0.5		X Walk 2 X Slope (%)	0.9
N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	Yes
	Road Slope (%)	0.7	N/A	Clear Space?	N/A
	Road X Slope (%)	0.1	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	6.6

Street 1 Name REAGAN DR
Stop Condition-Street 1 Signal
Street 2 Name W SUGAR CREEK RD
Stop Condition-Street 2 Signal

