

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 7185	Main Street: S I-85 EXIT 41 RA	Cross Street: W SUGAR CREEK RD	Location: NE
ADA ID: F095B1857BD0	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
Severity Score: 0.25			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Restripe Crosswalk. Remove & Replace Gutter.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.2.1, R305.2, R207.1, R304.5.3

Total Cost: \$ 4150.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	31.0	Yes	Ramp Slope (%)	7.2
Yes	Ramp Width (in)	54.0	Yes	Ramp XSlope (%)	3.5
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	7.6	Yes	Flare Slope RT (%)	4.0
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
No	Landing Length (in)	29.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	54.0	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	1.3	Yes	DWS Length (in)	24.0
Yes	Landing X Slope (%)	3.8	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	4.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	5.0
Yes	Gutter Lip Ht (in)	0.0	No	Gutter X Slope (%)	4.8
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To W		X Walk 2 Direction	To S
N/A	X Walk 1 Width (in)	113.0	N/A	X Walk 2 Width (in)	120.0
	X Walk 1 Slope (%)	4.8		X Walk 2 Slope (%)	1.5
	X Walk 1 X Slope (%)	0.8		X Walk 2 X Slope (%)	4.6
No	Ramp inside XWalk1?	No	No	Ramp inside XWalk2?	No
	Road Slope (%)	4.0	N/A	Clear Space?	Yes
	Road X Slope (%)	2.5	Yes	Clear Space to XWalk (in)	221.0
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name **W SUGAR CREEK RD**
 Stop Condition-Street 2 **Signal**
 Street 2 Name **S I-85 EXIT 41 RA**
 Stop Condition-Street 1 **Signal**

