


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 19082	Main Street: NATIONS_FORD_RD	Cross Street: SHARVIEW_CR	Location: NE
ADA ID: F1E1F0EC0DC0	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 28.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	48.0	No	Ramp Slope (%)	10.1
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	3.8
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Street 1 Name	NATIONS FORD RD		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
	Stop Condition-Street 2		N/A	Shared Landing?	N/A			
	Street 2 Name		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
	Stop Condition-Street 1		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
				X Walk 1 Direction	To W		X Walk 2 Direction	To S
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	4.2		X Walk 2 Slope (%)	1.9
				X Walk 1 X Slope (%)	2.6		X Walk 2 X Slope (%)	1.8
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
			Road Slope (%)	0.7	N/A	Clear Space?	N/A	
			Road X Slope (%)	0.8	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
			Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	
				No		Surface Condition? (G/P)	Poor	

