

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 53191 Main Street: JOHNSTON\_OEHLER\_PRIVATECEDS Street: JOHNSTON\_OEHLER\_RD Location: N

**ADA ID: F2101E9DB33A** Ramp Type: Perp Initial Pass/Fail: Pass **Overall Compliance: No Severity Score:** 

## Codes/Mitigation Info/Possible Solution



Street 1 Name	JOHNSTON OEHLER RD
Stop Condition-Street 2	None
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Possible Solutions:							
Gutter Ponding Observed.							
Surveyor Notes:							
N/A							
PROW/ADA:							
R302.7							
K302.7							

Total Cost:	\$ 500.00

Field Measurements/Component Compliance							
Comp	liance Description	Data	Comp	liance Description	Data		
N/A	Ramp Length (in)	95.0	Yes	Ramp Slope (%)	8.3		
Yes	Ramp Width (in)	95.0	Yes	Ramp XSlope (%)	1.0		
Yes	Flare Type L <b>Curbed_NoWa</b>	alkSurface	Yes	Flare Type RT	N/A		
Yes	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A		
N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No		
Yes	Landing Length (in)	71.0	Yes	DWS Provided?	Yes		
Yes	Landing Width (in)	95.0	Yes	DWS Contrast?	Yes		
Yes	Landing Slope (%)	1.2	Yes	DWS Length (in)	24.0		
Yes	Landing X Slope (%)	0.1	Yes	DWS Full Width?	Yes		
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	0.0		
N/A	Shared Landing?	No					
No	Gutter Ponding?	Yes	Yes	Gutter Slope (%)	1.0		
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.9		
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A		
	X Walk 1 Direction	To SW		X Walk 2 Direction	N/A		
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A		
	X Walk 1 Slope (%)	1.3		X Walk 2 Slope (%)	N/A		
	X Walk 1 X Slope (%)	0.7		X Walk 2 X Slope (%)	N/A		
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A		
	Road Slope (%)	N/A	N/A	Clear Space?	Yes		
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A		
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No		
	Obstruction Type			Storm Grate/Utility Type			
		N/A			N/A		
			Yes	Surface Condition? (G/P)	Good		
The Co	A CONTRACTOR OF THE PARTY OF TH						





