

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 32319	Main Street: ARDREY_KELL_RD	Cross Street: BRIDGEVIEW_LN	Location: NE
ADA ID: F31E99B6EFD7	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 33.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Remove & Replace Entire Ramp.					
	Surveyor Notes:		N/A					
	PROW/ADA:		Not Found, R304.5.1, R304.2.2, R304.5.3					
	Street 1 Name		ARDREY KELL RD					
	Stop Condition-Street 2		None					
	Street 2 Name		N/A					
	Stop Condition-Street 1		N/A					
	Total Cost:		\$ 1850.00					

