


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: N/A	Main Street: PROVIDENCE_RD	Cross Street: N/A	Location: SW
ADA ID: F3521DDAAA69	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 26.25

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance						
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	61.0	No	Ramp Slope (%)	13.8
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	4.2
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	N/A
PROW/ADA:		N/A	Shared Landing?	N/A				
Not Found, R304.2.2, R304.5.3		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	N/A
		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	No
			X Walk 1 Direction	To NE		X Walk 2 Direction	To NW	
		N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	N/A
			X Walk 1 Slope (%)	4.8		X Walk 2 Slope (%)	1.0	
			X Walk 1 X Slope (%)	0.7		X Walk 2 X Slope (%)	9.9	
		N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	N/A
			Road Slope (%)	3.0	N/A	Clear Space?	N/A	N/A
			Road X Slope (%)	14.9	N/A	Clear Space to XWalk (in)	N/A	N/A
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	N/A
			Obstruction Type			Storm Grate/Utility Type		
					N/A			N/A
					Yes	Surface Condition? (G/P)	Good	Good
Total Cost:		\$	3200.00					
Street 1 Name		PROVIDENCE RD						
Stop Condition-Street 2		None						
Street 2 Name		ENTRANCE						
Stop Condition-Street 1		StopSign						

Street 1 Name	PROVIDENCE RD
Stop Condition-Street 2	None
Street 2 Name	ENTRANCE
Stop Condition-Street 1	StopSign

Total Cost: \$ 3200.00

