

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 16599 Main Street: AMITY PL **Cross Street: REDDMAN RD** Location: SE ADA ID: F3996877373C Ramp Type: BlendTrans2 Initial Pass/Fail: Fail **Overall Compliance: No Severity Score:** 8.75

**Codes/Mitigation Info/Possible Solution** 

**AMITY PL** 

None



Street 1 Name Stop Condition-Street 1 Street 2 Name

**Remove & Replace Curb Ramp With** Two New Directional Ramps or Equivalent.

Surveyor Notes: N/A

PROW/ADA:

Not Found, R304.5.1

**REDDMAN RD** Stop Condition-Street 2 StopSign



Total Cost:



3200.00

Field Measurements/Component Compliance					
Compliance Description Data		Data	Comp	liance Description	Data
N/A	Ramp Length (in)	43.0	Yes	BlendTrans Slope (%)	2.6
No	Ramp Width (in)	45.0	Yes	BlendTrans XSlope (%)	0.2
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To N		X Walk 2 Direction	To W
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	4.5		X Walk 2 Slope (%)	4.3
	X Walk 1 X Slope (%)	1.9		X Walk 2 X Slope (%)	4.5
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	1.3		Clear Space?	N/A
	Road X Slope (%)	7.6	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type		l	Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			No	Curb Slope (%)	5.9