


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 2853	Main Street: CARDINAL_POINT_RD	Cross Street: BENFIELD_RD	Location: NE
ADA ID: F573896F3136	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 2.75	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	Compliance
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Remove & Replace Gutter.		Description			Description
			Data			Data
			N/A	Ramp Length (in)	100.0	Yes
			Yes	Ramp Width (in)	48.0	No
			N/A	Flare Type LT	Sloped	N/A
			N/A	Flare Slope LT (%)	10.6	Yes
			N/A	Flare Traversable LT?	Yes	N/A
			Yes	Landing Length (in)	72.0	Yes
			Yes	Landing Width (in)	49.5	Yes
Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.3, R304.2.2-Perp, R304.3.2-Para, R304.2.3			No	Landing Slope (%)	2.3	Yes
			No	Landing X Slope (%)	3.1	Yes
			N/A	Landing Curb? (Y/N)	No	Yes
			N/A	Shared Landing?	No	
			Yes	Gutter Ponding?	No	Yes
			Yes	Gutter Lip Ht (in)	0.0	No
			N/A	Painted X Walk1?	No	N/A
				X Walk 1 Direction	To W	
			N/A	X Walk 1 Width (in)	N/A	N/A
				X Walk 1 Slope (%)	0.9	
				X Walk 1 X Slope (%)	2.2	
			N/A	Ramp inside XWalk1?	N/A	Yes
				Road Slope (%)	2.4	N/A
				Road X Slope (%)	0.5	N/A
			Yes	Any Obstructions?	No	Yes
				Obstruction Type		
					N/A	N/A
						Yes
						Surface Condition? (G/P)
						Good

Total Cost: \$ 3950.00

