## cole

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10033959 Main Street: PARK_RD Cross Street: N/A								Location:	sw
ADA ID: F72FB5EB50E1	Ramp Type: PerpDiag			Initial Pass/Fail: Fail Overall Compliance: No					12.5
				· · · · ·					
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
E.	5.	Possible Solutions: Remove & Replace Curb Ramp Wit Two New Directional Ramps or Equivalent.					liance Description	Data	
			Nith	N/A	Ramp Length (in)	59.0	No	Ramp Slope (%)	10.5
				Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	0.5
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
A CARLER AND A				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
AND				N/A	Shared Landing?	N/A			
and a second and the		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
the set with		Not Found, R304.2.2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
4.477.684		,		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
the states					X Walk 1 Direction	To E		X Walk 2 Direction	To N
	11.12%			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	PARK RD				X Walk 1 Slope (%)	0.7		X Walk 2 Slope (%)	0.5
Stop Condition-Street 2	None				X Walk 1 X Slope (%)	1.3		X Walk 2 X Slope (%)	1.6
Street 2 Name	ENTRANCE			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	StopSign				Road Slope (%)	0.2	N/A	Clear Space?	N/A
					Road X Slope (%)	0.7	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost: \$	3200.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A

Yes Surface Condition? (G/P)

Good

