


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 49659	Main Street: GREEN_TRAIL_LN	Cross Street: WINDING_PATH_WY	Location: SW
ADA ID: F74E8DEA6D08	Ramp Type: IslandPerp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
 <p>Street 1 Name GREEN TRAIL LN</p> <p>Stop Condition-Street 2 StopSign</p> <p>Street 2 Name N/A</p> <p>Stop Condition-Street 1 N/A</p>	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	66.0	No	Ramp Slope (%)	8.4
			Yes	Ramp Width (in)	71.0	Yes	Ramp XSlope (%)	1.4
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	N/A
		N/A	Shared Landing?	N/A				
		N/A	Gutter Ponding?	Yes	N/A	Gutter Slope (%)	N/A	N/A
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	N/A
		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	N/A
			X Walk 1 Direction	To SW		X Walk 2 Direction	N/A	N/A
		N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	N/A
			X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A	N/A
			X Walk 1 X Slope (%)	1.8		X Walk 2 X Slope (%)	N/A	N/A
		N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	N/A
			Road Slope (%)	N/A	N/A	Clear Space?	N/A	N/A
			Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	N/A
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	N/A
			Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	N/A
					Yes	Surface Condition? (G/P)	Good	Good
Total Cost:		\$ 3400.00						

Street 1 Name	GREEN TRAIL LN
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Total Cost: \$ 3400.00

