

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: N/A Main Street: CLEMS_BRANCH_DR Cross Street: GREAT_FUTURE_DR Location: N

ADA ID: F759AE4D146E Ramp Type: ParaDiag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 13.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
Stop Condition-Street 1
Street 2 Name
Stop Condition-Street 2

CLEMS BRANCH DR None GREAT FUTURE DR None Possible Solutions:

Remove & Replace Curb Ramp With
Two New Directional Ramps or
Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

R304.3.2, R304.5.3

Total Cost: \$ 3200.00

Overallance Description Date Overallance Description					
Compliance Description		Data	Compliance Description		Data
N/A	Ramp Length LT (in)	53.0	N/A	Ramp Length RT (in)	49.0
Yes	Ramp Width LT (in)	60.0	Yes	Ramp Width RT (in)	60.0
No	Ramp Slope LT (%)	9.5	Yes	Ramp Slope RT (%)	5.2
No	Ramp XSlope LT (%)	3.3	No	Ramp XSlope RT (%)	2.1
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	120.0
	X Walk 1 Slope (%)	7.5		X Walk 2 Slope (%)	2.5
	X Walk 1 X Slope (%)	2.9		X Walk 2 X Slope (%)	5.6
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	Yes
	Road Slope (%)	4.5	N/A	Clear Space?	N/A
	Road X Slope (%)	3.7	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	11.4
en.			,	(/	





