

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

31.0

46.0

9.1

2.4

2.5

7.5

N/A

No

To S

N/A

4.1

3.3

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Good 13.3

Intersection ID: N/A Main Street: DERRYFIELD_DR Cross Street: HAMPTON_WAY_DR Location: NE
ADA ID: F79F8183BBF1 Ramp Type: Combination1Diag Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

Compliance Description

Data

0.4

N/A

N/A

N/A

Yes

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)

Any Obstruction?

Obstruction Type

Curb Slope (%)



Street 1 Name
Stop Condition-Street 1
Street 2 Name
Stop Condition-Street 2

None HAMPTON WAY DR StopSign DERRYFIELD DR Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.1, R304.5.1, R304.5.3, R304.3.2

Total Cost:

N/A Ramp Length RT (in) N/A Ramp Length LT (in) 38.0 46.0 No No Ramp Width LT (in) Ramp Width RT (in) 8.7 No No Ramp Slope LT (%) Ramp Slope RT (%) Ramp XSlope LT (%) No Ramp XSlope RT (%) Yes 1.6 N/A Ramp Length (in) 47.0 Yes Ramp Slope (%) 39.0 No Ramp XSlope (%) No Ramp Width (in) N/A Flare Type LT N/A N/A Flare Type RT N/A N/A N/A Flare Slope LT (%) Flare Slope RT (%) N/A Flare Traversable LT? N/A N/A Flare Traversable RT? N/A Landing Length (in) N/A N/A DWS Provided? N/A N/A N/A **DWS Contrast?** Landing Width (in) N/A Landing Slope (%) N/A N/A DWS Length (in) N/A Landing X Slope (%) N/A N/A DWS Full Width? N/A Landing Curb? (Y/N) N/A N/A DWS Offset (in) N/A Shared Landing? N/A N/A **Gutter Ponding?** N/A N/A Gutter Slope (%) N/A N/A Gutter Lip Ht (in) N/A Gutter X Slope (%) Painted X Walk1? N/A N/A No Painted X Walk2? To W X Walk 1 Direction X Walk 2 Direction X Walk 1 Width (in) N/A X Walk 2 Width (in) 1.6 X Walk 2 Slope (%) X Walk 1 Slope (%) X Walk 1 X Slope (%) 5.2 X Walk 2 X Slope (%) N/A N/A N/A Ramp inside XWalk1? Ramp inside XWalk2? Road Slope (%) 5.2 Clear Space?

Compliance Description







3200.00