


Intersection ID: 9944	Main Street: CHESHIRE_AV	Cross Street: TUCKASEEGEE_RD	Location:	E
ADA ID: F91944E4E97A	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 8.75

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		<b>Compliance</b>			<b>Description</b>			<b>Data</b>	
	<b>Remove &amp; Replace Entire Ramp.</b>		<b>N/A</b>		Ramp Length (in)	<b>60.0</b>	<b>Yes</b>	Ramp Slope (%)	<b>8.1</b>	
			<b>No</b>		Ramp Width (in)	<b>42.0</b>	<b>Yes</b>	Ramp XSlope (%)	<b>1.5</b>	
			<b>N/A</b>		Flare Type LT	<b>N/A</b>	<b>N/A</b>	Flare Type RT	<b>N/A</b>	
			<b>N/A</b>		Flare Slope LT (%)	<b>N/A</b>	<b>N/A</b>	Flare Slope RT (%)	<b>N/A</b>	
			<b>N/A</b>		Flare Traversable LT?	<b>N/A</b>	<b>N/A</b>	Flare Traversable RT?	<b>N/A</b>	
			<b>N/A</b>		Landing Length (in)	<b>N/A</b>	<b>N/A</b>	DWS Provided?	<b>N/A</b>	
			<b>N/A</b>		Landing Width (in)	<b>N/A</b>	<b>N/A</b>	DWS Contrast?	<b>N/A</b>	
			<b>N/A</b>		Landing Slope (%)	<b>N/A</b>	<b>N/A</b>	DWS Length (in)	<b>N/A</b>	
			<b>N/A</b>		Landing X Slope (%)	<b>N/A</b>	<b>N/A</b>	DWS Full Width?	<b>N/A</b>	
Surveyor Notes:	<b>N/A</b>		<b>N/A</b>		Landing Curb? (Y/N)	<b>N/A</b>	<b>N/A</b>	DWS Offset (in)	<b>N/A</b>	
			<b>N/A</b>		Shared Landing?	<b>N/A</b>				
	PROW/ADA:		<b>N/A</b>		Gutter Ponding?	<b>N/A</b>	<b>N/A</b>	Gutter Slope (%)	<b>N/A</b>	
	<b>Not Found, R304.5.1</b>		<b>N/A</b>		Gutter Lip Ht (in)	<b>0.8</b>	<b>N/A</b>	Gutter X Slope (%)	<b>N/A</b>	
			<b>N/A</b>		Painted X Walk1?	<b>No</b>	<b>N/A</b>	Painted X Walk2?	<b>N/A</b>	
					X Walk 1 Direction	<b>To NW</b>		X Walk 2 Direction	<b>N/A</b>	
			<b>N/A</b>		X Walk 1 Width (in)	<b>N/A</b>	<b>N/A</b>	X Walk 2 Width (in)	<b>N/A</b>	
					X Walk 1 Slope (%)	<b>3.1</b>		X Walk 2 Slope (%)	<b>N/A</b>	
					X Walk 1 X Slope (%)	<b>1.7</b>		X Walk 2 X Slope (%)	<b>N/A</b>	
			<b>N/A</b>		Ramp inside XWalk1?	<b>N/A</b>	<b>N/A</b>	Ramp inside XWalk2?	<b>N/A</b>	
				Road Slope (%)	<b>N/A</b>	<b>N/A</b>	Clear Space?	<b>N/A</b>		
				Road X Slope (%)	<b>N/A</b>	<b>N/A</b>	Clear Space to XWalk (in)	<b>N/A</b>		
		<b>N/A</b>		Any Obstructions?	<b>N/A</b>	<b>N/A</b>	Storm Grate/Utility Hazard?	<b>N/A</b>		
				Obstruction Type			Storm Grate/Utility Type			
						<b>N/A</b>			<b>N/A</b>	
							<b>Yes</b>	Surface Condition? (G/P)	<b>Good</b>	
Street 1 Name		<b>CHESHIRE AV</b>								
Stop Condition-Street 2		<b>StopSign</b>								
Street 2 Name		<b>N/A</b>								
Stop Condition-Street 1		<b>N/A</b>								
Total Cost:		<b>\$ 1850.00</b>								

