cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 10035421	35421 Main Street: RANDOLPH_RD		Cross Street: N/A					NW	
ADA ID: FA19F40C7EA2	D: FA19F40C7EA2 Ramp Type: PerpDiag		Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	30	
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance						
	Possible Solutions:	<u>c</u>	Compliance Description Data			Compliance Description Data			
	Remove & Replace Curb Ramp	With N	I/A	Ramp Length (in)	56.0	No	Ramp Slope (%)	11.6	
	Two New Directional Ramps or		lo	Ramp Width (in)	35.0	Yes	Ramp XSlope (%)	1.6	
	Equivalent.	N	I/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
		N	I/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
		N	I/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
		N	I/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
	Surveyor Notes:	N	I/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
	N/A	N	I/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
		N	I/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
		N	I/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
		N	I/A	Shared Landing?	N/A				
in the second second	PROW/ADA:	N	I/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
and all and a	Not Found, R304.5.1, R304.2.2	Ν	I/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
		N	I/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
				X Walk 1 Direction	To SE		X Walk 2 Direction	To NE	
		N	I/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name ENT	TRANCE			X Walk 1 Slope (%)	6.2		X Walk 2 Slope (%)	5.1	
Stop Condition-Street 2 S	StopSign			X Walk 1 X Slope (%)	5.2		X Walk 2 X Slope (%)	6.9	
Street 2 Name RANDO	DLPH RD	N	I/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1	None			Road Slope (%)	0.8	N/A	Clear Space?	N/A	
				Road X Slope (%)	8.6	N/A	Clear Space to XWalk (in)	N/A	
		Ν	I/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost: \$	3200.00		Obstruction Type			Storm Grate/Utility Type		
					N/A			N/A	

Yes Surface Condition? (G/P)

Good

