

Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 10680	Main Street: MATHESON_AV	Cross Street: PINCKNEY_AV	Location: NE
ADA ID: FCB87301B63A	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 7.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	87.5	Yes
			Yes	Ramp Width (in)	97.5	Yes
			Yes	Ramp Slope (%)	6.5	Yes
			Yes	Ramp XSlope (%)	2.0	
			N/A	Flare Type LT	N/A	N/A
			N/A	Flare Slope LT (%)	N/A	No
			N/A	Flare Traversable LT?	N/A	N/A
	Surveyor Notes:		Yes	Landing Length (in)	57.0	Yes
	N/A		Yes	Landing Width (in)	69.5	Yes
			No	Landing Slope (%)	3.6	Yes
			Yes	Landing X Slope (%)	0.7	No
	PROW/ADA:		N/A	Landing Curb? (Y/N)	N/A	Yes
	Not Found, R304.2.2-Perp, R304.3.2-Para, R304.2.3, R305.1.4, R305.2		N/A	Shared Landing?	No	No
			Yes	Gutter Ponding?	No	Yes
			Yes	Gutter Lip Ht (in)	0.0	Yes
			N/A	Painted X Walk1?	No	
				X Walk 1 Direction	To NW	
				X Walk 1 Width (in)	N/A	
				X Walk 1 Slope (%)	1.8	N/A
				X Walk 1 X Slope (%)	1.1	Yes
			N/A	Ramp inside XWalk1?	N/A	
			Yes	Any Obstructions?	No	
				Obstruction Type		
Total Cost:		\$ 1600.00				
			N/A			No
						Yes
						Good
						17.6

Street 1 Name	PINCKNEY AV
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

