

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

8.5

3.0

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Intersection ID: 10034710 Main Street: POINDEXTER DR Cross Street: N/A Location: Initial Pass/Fail: Fail **Overall Compliance: No** ADA ID: FD5C43580091 Ramp Type: Perp Severity Score: 13.75

Compliance Description

Ramp Length (in)

Ramp Width (in)

Flare Slope LT (%)

Landing Length (in)

Landing Width (in)

Landing Slope (%)

Landing X Slope (%)

Flare Traversable LT?

Flare Type LT

N/A

Yes

N/A

N/A

N/A

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

No

No

N/A

N/A

N/A

N/A

N/A

N/A

N/A

Compliance Description

Ramp Slope (%)

Flare Type RT

Ramp XSlope (%)

Flare Slope RT (%)

DWS Provided?

DWS Contrast?

DWS Length (in)

DWS Full Width?

Flare Traversable RT?

Data

72.0

59.0

N/A

N/A


N/A

N/A

N/A

N/A

N/A



POINDEXTER DR Street 1 Name Stop Condition-Street 2 None N/A Street 2 Name Stop Condition-Street 1 N/A Possible Solutions: Remove & Replace Entire Ramp. Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2, R304.5.3

N/A N/A N/A N/A Total Cost: 1850.00





