


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10031496	Main Street: MCKEE_RD	Cross Street: N/A	Location: SW
ADA ID: FDB70167BCE6	Ramp Type: BlendTrans2	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 1.25	

Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
	Possible Solutions:			Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.			N/A	Ramp Length (in)	71.5	Yes	BlendTrans Slope (%)	0.7
				Yes	Ramp Width (in)	72.0	No	BlendTrans XSlope (%)	2.5
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
				N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
				N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
				N/A	Shared Landing?	N/A			
				N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
				N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
					X Walk 1 Direction	To NE		X Walk 2 Direction	N/A
					X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
					X Walk 1 Slope (%)	0.1		X Walk 2 Slope (%)	N/A
					X Walk 1 X Slope (%)	2.0		X Walk 2 X Slope (%)	N/A
				N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	2.0		Clear Space?	N/A	
				Road X Slope (%)	0.1	N/A	Clear Space to XWalk (in)	N/A	
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
				Obstruction Type			Storm Grate/Utility Type		
					N/A			N/A	
						Yes	Surface Condition? (G/P)	Good	
						N/A	Curb Slope (%)	2.1	
Street 1 Name			ENTRANCE						
Stop Condition-Street 1			StopSign						
Street 2 Name			N/A						
Stop Condition-Street 2			N/A						
Total Cost:			\$	3200.00					

Street 1 Name	ENTRANCE
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

