

Access Compliance Report Public Rights-of-Way (Pedestrian Signals)



Data

N/A

N/A

N/A

No

N/A

Intersection ID: N/A **Main Street:** Cross Street: N/A Location: N/A

Severity Score: BTN 1:N/A BTN 2: N/A No BTN: ADA ID: 33E726E881E4 Signal Type: One Push Button-Non APS **Overall Compliance: No** N/A

Compliance Description

N/A Signal Buttons Required?

Additional Button Present?

How Many Ped Street Xings?

Yes B 1 Sign Lettering & Contrast?

N/A B 1 FWD Approach Constrained?

No B 1 FWD Approach Reach (in)

N/A B 1 FWD Approach Width (in)

N/A B 1 FWD Approach Obstruction?

N/A B 1 PARA Approach Constrained?

N/A B 1 FWD Approach Obstruction Dist (in)

Button Count

N/A B 1 Sign Present?

Yes B 1 Sign Purpose?

Yes B 1 Parallel To XWalk?

Yes B 1 Clear Floor Space? N/A B 1 FWD Approach?

N/A B 1 PARA Approach?

No B 1 DistanceTo Curb (in)

Yes B 1 Diameter (in)

Yes B 1 PAR to Button?

Yes B 1 PAR to XWalk?

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

Compliance Description

Button1 N/A Distant to Additional Button (in)

Yes N/A B 2 Sign Present?

Yes N/A B 2 Sign Purpose?

Yes N/A B 2 Parallel To XWalk?

Yes N/A B 2 Clear Floor Space?

Yes N/A B 2 PAR to Button?

Yes N/A B 2 PAR to XWalk?

Yes N/A B 2 FWD Approach?

Yes N/A B 2 PARA Approach?

84.0 N/A B 2 DistanceTo Curb (in)

2.0 N/A B 2 Diameter (in)

Additional Button ID

N/A N/A Additional Ped Posts Required

Yes N/A B 2 Sign Lettering & Contrast?

No N/A B 2 FWD Approach Constrained?

No N/A B 2 FWD Approach Obstruction?

No N/A B 2 PARA Approach Constrained?

N/A N/A B 2 FWD Approach ObstructionDist (in)

6.0 N/A B 2 FWD Approach Reach (in)

N/A N/A B 2 FWD Approach Width (in)

Located In An Island/Median?

Data

No



N/A B 1 Extended Press Feature?

N/A B 1 Tone Audible Range?

Possible Solutions: Replace Signal Push Button With APS Button on New Post. Remove & Relocate Sign.

Surveyor Notes: N/A

PROW/ADA: TMUTCD 4e.08, R404.2, R404.3, R406.2

Total Cost:

No N/A B 2 Extended Press Feature?

No N/A B 2 Tone Audible Range?



	\$	650.00
(10 KM)		
	*	
		1

			1	Yes	B 1 PARA Approach Reach (in	n) 6 .	.0 N/A	B 2 PARA Approach Reach (in)	N/A
				N/A	B 1 PARA Approach Width (in)) N /	A N/A	B 2 PARA Approach Width (in)	N/A
				N/A	B 1 PARA Approach Obstruction	on? N	o N/A	B 2 PARA Approach Obstruction?	N/A
APS Compliance			N/A	B 1 PARA Approach Obstruction	on Dist (in) N/	A N/A	B 2 PARA Approach ObstructionDist (in)	N/A	
Is Button 1 APS or Non-APS?	NonAPS	Is Button 2 APS or Non-APS?	N/A	No	B 1 Clear Floor Space Slope ((%) 3.	.1 N/A	B 2 Clear Floor Space Slope (%)	N/A
N/A B 1 VibroTact Arrow?	No N/A	A B 2 VibroTact Arrow?	N/A	No	B 1 Clear Floor Space XSlope	e (%) 3 .	.2 N/A	B 2 Clear Floor Space XSlope (%)	N/A
N/A B 1 VibroTact Parallel to Xing?	No N/A	A B 2 VibroTact Parallel to Xing?	N/A	N/A	B 1 PAR Slope (%)	1.	.7 N/A	B 2 PAR Slope (%)	N/A
N/A B 1 VibroTact Contrast	No N/A	A B 2 VibroTact Contrast	N/A	Yes	B 1 Height (in)	48.	.0 N/A	B 2 Height (in)	N/A
N/A B 1 Pilot Light?	No N/A	A B 2 Pilot Light?	N/A	Yes	B 1 Pressure (#)	2.	.0 N/A	B 2 Pressure (#)	N/A
N/A B 1 Pilot Light Illumination?	No N/A	A B 2 Pilot Light Illumination?	N/A	Yes	B 1 Closed Fist Operation?	Ye	s N/A	B 2 Closed Fist Operation?	N/A
N/A B 1 Verbal Walk Cycle?	No N/A	A B 2 Verbal Walk Cycle?	N/A	MUTCD Compliance					
N/A B 1 Verbal Message Audible?	No N/A	A B 2 Verbal Message Audible?	N/A	Yes	B 1 Clear Xing Direction?	ClearlyMarke	d N/A	B 2 Clear Xing Direction?	N/A
N/A B 1 Locator Tone?	No N/A	A B 2 Locator Tone?	N/A		B 1 Crossing Direction	To N	E	B 2 Crossing Direction	N/A
N/A B 1 Percussive Walk Cycle?	No N/A	A B 2 Percussive Walk Cycle?	N/A	Yes	B 1 DistanceTo XWalk (in)	36.	.0 N/A	B 2 DistanceTo XWalk (in)	N/A

N/A

N/A