

Access Compliance Report Public Rights-of-Way (Pedestrian Signals)



Intersection ID: N/A Main Street: Cross Street: N/A Location: N/A

ADA ID: 9A3F75E2B5F5 Signal Type: One Push Button-Non APS Overall Compliance: No Severity Score: BTN 1:N/A BTN 2: N/A No BTN: N/A

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



N/A B 1 Extended Press Feature?

N/A B 1 Tone Audible Range?

Possible Solutions: Replace Signal Push Button With APS Button on New Post. Remove & Relocate Sign.

Surveyor Notes: N/A

PROW/ADA: TMUTCD 4e.08, R406.2

Total Cost:

No N/A B 2 Extended Press Feature?

No N/A B 2 Tone Audible Range?

650.00



	Con	pliance Description	Data	Com	pliance Description	Data
		Button Count	Button1	Yes	Distant to Additional Button (in)	173.0
		Additional Button Present?	Yes		Additional Button ID 90702EF	2F123
	N/A	Signal Buttons Required?	N/A	N/A	Additional Ped Posts Required	N/A
		How Many Ped Street Xings?	1		Located In An Island/Median?	No
	N/A	B 1 Sign Present?	Yes	N/A	B 2 Sign Present?	N/A
	Yes	B 1 Sign Purpose?	Yes	N/A	B 2 Sign Purpose?	N/A
	Yes	B 1 Sign Lettering & Contrast?	Yes	N/A	B 2 Sign Lettering & Contrast?	N/A
	Yes	B 1 Parallel To XWalk?	Yes	N/A	B 2 Parallel To XWalk?	N/A
	Yes	B 1 PAR to Button?	Yes	N/A	B 2 PAR to Button?	N/A
	Yes	B 1 PAR to XWalk?	Yes	N/A	B 2 PAR to XWalk?	N/A
	Yes	B 1 Clear Floor Space?	Yes	N/A	B 2 Clear Floor Space?	N/A
	N/A	B 1 FWD Approach?	Yes	N/A	B 2 FWD Approach?	N/A
.00	N/A	B 1 FWD Approach Constrained?	No	N/A	B 2 FWD Approach Constrained?	N/A
	No	B 1 FWD Approach Reach (in)	7.0	N/A	B 2 FWD Approach Reach (in)	N/A
	N/A	B 1 FWD Approach Width (in)	60.0	N/A	B 2 FWD Approach Width (in)	N/A
	N/A	B 1 FWD Approach Obstruction?	Yes	N/A	B 2 FWD Approach Obstruction?	N/A
	N/A	B 1 FWD Approach Obstruction Dist (in	n) 5.0	N/A	B 2 FWD Approach ObstructionDist (in)	N/A
	N/A	B 1 PARA Approach?	Yes	N/A	B 2 PARA Approach?	N/A
	N/A	B 1 PARA Approach Constrained?	No	N/A	B 2 PARA Approach Constrained?	N/A
	Yes	B 1 PARA Approach Reach (in)	7.0	N/A	B 2 PARA Approach Reach (in)	N/A

86.0 N/A B 2 DistanceTo Curb (in)

2.0 N/A B 2 Diameter (in)

N/A

N/A



1000				N/A B 1 PARA Approach Width (in)	60.0 N/A	A B 2 PARA Approach Width (in)	N/A
				N/A B 1 PARA Approach Obstruction?	Yes N/A	A B 2 PARA Approach Obstruction?	N/A
	APS Complia	ince	N/A B 1 PARA Approach Obstruction Dist	(in) 5.0 N/A	A B 2 PARA Approach ObstructionDist (in)	n) N/A	
Is Button 1 APS or Non-APS?	NonAPS	Is Button 2 APS or Non-APS?	N/A	Yes B 1 Clear Floor Space Slope (%)	1.1 N/A	A B 2 Clear Floor Space Slope (%)	N/A
N/A B 1 VibroTact Arrow?	No N/A	A B 2 VibroTact Arrow?	N/A	Yes B 1 Clear Floor Space XSlope (%)	1.9 N/A	A B 2 Clear Floor Space XSlope (%)	N/A
N/A B 1 VibroTact Parallel to Xing?	No N/F	A B 2 VibroTact Parallel to Xing?	N/A	N/A B 1 PAR Slope (%)	6.2 N/A	A B 2 PAR Slope (%)	N/A
N/A B 1 VibroTact Contrast	No N/F	A B 2 VibroTact Contrast	N/A	Yes B 1 Height (in)	37.0 N/A	A B 2 Height (in)	N/A
N/A B 1 Pilot Light?	No N/A	A B 2 Pilot Light?	N/A	Yes B 1 Pressure (#)	1.5 N/A	A B 2 Pressure (#)	N/A
N/A B 1 Pilot Light Illumination?	No N/A	A B 2 Pilot Light Illumination?	N/A	Yes B 1 Closed Fist Operation?	Yes N/A	A B 2 Closed Fist Operation?	N/A
N/A B 1 Verbal Walk Cycle?		A B 2 Verbal Walk Cycle?	N/A		MUTCD Com	UTCD Compliance	
N/A B 1 Verbal Message Audible?	No N/A	A B 2 Verbal Message Audible?	N/A	Yes B 1 Clear Xing Direction? Clear	rlyMarked N/A	A B 2 Clear Xing Direction?	N/A
N/A B 1 Locator Tone?	No N/F	A B 2 Locator Tone?	N/A	B 1 Crossing Direction	To SE	B 2 Crossing Direction	N/A
N/A B 1 Percussive Walk Cycle?	No N/A	A B 2 Percussive Walk Cycle?	N/A	Yes B 1 DistanceTo XWalk (in)	0.0 N/A	A B 2 DistanceTo XWalk (in)	N/A

N/A

N/A

No B 1 DistanceTo Curb (in)

Yes B 1 Diameter (in)