

Access Compliance Report Public Rights-of-Way (Pedestrian Signals)



Data

12D2BB00536F

152.0

N/A

Yes

N/A

Main Street: Intersection ID: N/A Cross Street: N/A Location: N/A

Signal Type: One Push Button-Non APS Severity Score: BTN 1:N/A BTN 2: N/A No BTN: N/A ADA ID: 9CAE00E5AA80 **Overall Compliance: No**

Button Count

Yes B 1 Clear Floor Space? N/A B 1 FWD Approach?

No B 1 FWD Approach Reach (in)

N/A B 1 FWD Approach Width (in)

N/A B 1 FWD Approach Obstruction?

N/A B 1 FWD Approach Obstruction Dist (in)

Additional Button Present?

How Many Ped Street Xings?

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance

Compliance Description

Button1 Yes Distant to Additional Button (in)

Yes N/A B 2 Sign Present?

Yes N/A B 2 Sign Purpose?

Yes N/A B 2 PAR to Button?

Yes N/A B 2 PAR to XWalk?

Yes N/A B 2 FWD Approach?

Yes N/A B 2 Parallel To XWalk?

Yes N/A B 2 Clear Floor Space?

Additional Button ID

N/A N/A Additional Ped Posts Required

Yes N/A B 2 Sign Lettering & Contrast?

No N/A B 2 FWD Approach Constrained?

12.0 N/A B 2 FWD Approach Reach (in)

N/A N/A B 2 FWD Approach Width (in)

Yes N/A B 2 FWD Approach Obstruction?

10.0 N/A B 2 FWD Approach ObstructionDist (in)

Located In An Island/Median?

Data

Yes



Compliance Description Possible Solutions: Provide Push Button Extension. Remove and Replace Clear Space. N/A Signal Buttons Required? Surveyor Notes: N/A N/A B 1 Sign Present? Yes B 1 Sign Purpose? Yes B 1 Sign Lettering & Contrast? Yes B 1 Parallel To XWalk? PROW/ADA: R404.2, R404.3, R406.2, R404.7.3 Yes B 1 PAR to Button? Yes B 1 PAR to XWalk?

900.00 N/A B 1 FWD Approach Constrained?



Total Cost:



					N/A B 1 PARA Approach?	Yes N/A	B 2 PARA Approach?	N/A
					N/A B 1 PARA Approach Constraine	ed? No N/A	B 2 PARA Approach Constrained?	N/A
		Allingua			No B 1 PARA Approach Reach (in)	12.0 N/A	B 2 PARA Approach Reach (in)	N/A
					N/A B 1 PARA Approach Width (in)	N/A N/A	B 2 PARA Approach Width (in)	N/A
					N/A B 1 PARA Approach Obstruction	n? Yes N/A	B 2 PARA Approach Obstruction?	N/A
APS Compliance					N/A B 1 PARA Approach Obstruction	n Dist (in) 10.0 N/A	B 2 PARA Approach ObstructionDist (i	in) N/A
	Is Button 1 APS or Non-APS?	NonAPS	Is Button 2 APS or Non-APS?	N/A	No B 1 Clear Floor Space Slope (%	6) 4.3 N/A	B 2 Clear Floor Space Slope (%)	N/A
N/A	B 1 VibroTact Arrow?	N/A N/A	B 2 VibroTact Arrow?	N/A	Yes B 1 Clear Floor Space XSlope	(%) 1.2 N/A	B 2 Clear Floor Space XSlope (%)	N/A
N/A	B 1 VibroTact Parallel to Xing?	N/A N/A	B 2 VibroTact Parallel to Xing?	N/A	N/A B 1 PAR Slope (%)	4.0 N/A	B 2 PAR Slope (%)	N/A
N/A	B 1 VibroTact Contrast	N/A N/A	B 2 VibroTact Contrast	N/A	Yes B 1 Height (in)	38.0 N/A	B 2 Height (in)	N/A
N/A	B 1 Pilot Light?	N/A N/A	B 2 Pilot Light?	N/A	Yes B 1 Pressure (#)	1.5 N/A	B 2 Pressure (#)	N/A
N/A	B 1 Pilot Light Illumination?	N/A N/A	B 2 Pilot Light Illumination?	N/A	Yes B 1 Closed Fist Operation?	Yes N/A	B 2 Closed Fist Operation?	N/A
N/A	B 1 Verbal Walk Cycle?	N/A N/A	B 2 Verbal Walk Cycle?	N/A	MUTCD Compliance			
N/A	B 1 Verbal Message Audible?	N/A N/A	B 2 Verbal Message Audible?	N/A	Yes B 1 Clear Xing Direction?	ClearlyMarked N/A	B 2 Clear Xing Direction?	N/A
N/A	B 1 Locator Tone?	N/A N/A	B 2 Locator Tone?	N/A	B 1 Crossing Direction	To NE	B 2 Crossing Direction	N/A
N/A	B 1 Percussive Walk Cycle?	N/A N/A	B 2 Percussive Walk Cycle?	N/A	Yes B 1 DistanceTo XWalk (in)	0.0 N/A	B 2 DistanceTo XWalk (in)	N/A
N/A	B 1 Extended Press Feature?	N/A N/A	B 2 Extended Press Feature?	N/A	Yes B 1 DistanceTo Curb (in)	28.0 N/A	B 2 DistanceTo Curb (in)	N/A
N/A	B 1 Tone Audible Range?	N/A N/A	B 2 Tone Audible Range?	N/A	Yes B 1 Diameter (in)	2.0 N/A	B 2 Diameter (in)	N/A