

# Access Compliance Report

## Public Rights-of-Way

### (Pedestrian Signals)

|                                         |                                   |                                         |                                                  |
|-----------------------------------------|-----------------------------------|-----------------------------------------|--------------------------------------------------|
| Intersection ID: N/A                    | Main Street:                      | Cross Street: N/A                       | Location: N/A                                    |
| ADA ID: B6A21CB6137E                    | Signal Type: Two Push Buttons-APS | Overall Compliance: No                  | Severity Score: BTN 1:N/A BTN 2: N/A No BTN: N/A |
| Codes/Mitigation Info/Possible Solution |                                   | Field Measurements/Component Compliance |                                                  |




Possible Solutions: Replace Signal Push Button With APS Button on New Post. Remove & Relocate Sign.

Surveyor Notes: N/A

PROW/ADA: TMUTCD 4e.08, R404.2, R406.2,

Total Cost: \$ 1300.00



| Compliance | Description                             | Data    | Compliance | Description                            | Data |
|------------|-----------------------------------------|---------|------------|----------------------------------------|------|
|            | Button Count                            | Button2 | N/A        | Distant to Additional Button (in)      | N/A  |
|            | Additional Button Present?              | No      |            | Additional Button ID                   | N/A  |
| N/A        | Signal Buttons Required?                | N/A     | N/A        | Additional Ped Posts Required          | N/A  |
|            | How Many Ped Street Xings?              | 2       |            | Located In An Island/Median?           | No   |
| N/A        | B 1 Sign Present?                       | Yes     | N/A        | B 2 Sign Present?                      | Yes  |
| Yes        | B 1 Sign Purpose?                       | Yes     | Yes        | B 2 Sign Purpose?                      | Yes  |
| Yes        | B 1 Sign Lettering & Contrast?          | Yes     | Yes        | B 2 Sign Lettering & Contrast?         | Yes  |
| Yes        | B 1 Parallel To XWalk?                  | Yes     | Yes        | B 2 Parallel To XWalk?                 | Yes  |
| Yes        | B 1 PAR to Button?                      | Yes     | Yes        | B 2 PAR to Button?                     | Yes  |
| Yes        | B 1 PAR to XWalk?                       | Yes     | Yes        | B 2 PAR to XWalk?                      | Yes  |
| Yes        | B 1 Clear Floor Space?                  | Yes     | Yes        | B 2 Clear Floor Space?                 | Yes  |
| N/A        | B 1 FWD Approach?                       | Yes     | N/A        | B 2 FWD Approach?                      | Yes  |
| N/A        | B 1 FWD Approach Constrained?           | No      | N/A        | B 2 FWD Approach Constrained?          | No   |
| No         | B 1 FWD Approach Reach (in)             | 6.0     | No         | B 2 FWD Approach Reach (in)            | 4.0  |
| N/A        | B 1 FWD Approach Width (in)             | N/A     | N/A        | B 2 FWD Approach Width (in)            | N/A  |
| N/A        | B 1 FWD Approach Obstruction?           | No      | N/A        | B 2 FWD Approach Obstruction?          | No   |
| N/A        | B 1 FWD Approach Obstruction Dist (in)  | N/A     | N/A        | B 2 FWD Approach ObstructionDist (in)  | N/A  |
| N/A        | B 1 PARA Approach?                      | Yes     | N/A        | B 2 PARA Approach?                     | Yes  |
| N/A        | B 1 PARA Approach Constrained?          | No      | N/A        | B 2 PARA Approach Constrained?         | No   |
| Yes        | B 1 PARA Approach Reach (in)            | 4.0     | Yes        | B 2 PARA Approach Reach (in)           | 0.0  |
| N/A        | B 1 PARA Approach Width (in)            | N/A     | N/A        | B 2 PARA Approach Width (in)           | N/A  |
| N/A        | B 1 PARA Approach Obstruction?          | No      | N/A        | B 2 PARA Approach Obstruction?         | No   |
| N/A        | B 1 PARA Approach Obstruction Dist (in) | N/A     | N/A        | B 2 PARA Approach ObstructionDist (in) | N/A  |
| Yes        | B 1 Clear Floor Space Slope (%)         | 0.1     | Yes        | B 2 Clear Floor Space Slope (%)        | 0.5  |
| No         | B 1 Clear Floor Space XSlope (%)        | 5.6     | No         | B 2 Clear Floor Space XSlope (%)       | 4.7  |
| N/A        | B 1 PAR Slope (%)                       | 0.3     | N/A        | B 2 PAR Slope (%)                      | 0.6  |
| Yes        | B 1 Height (in)                         | 34.0    | Yes        | B 2 Height (in)                        | 34.0 |
| Yes        | B 1 Pressure (#)                        | 3.0     | Yes        | B 2 Pressure (#)                       | 3.0  |
| Yes        | B 1 Closed Fist Operation?              | Yes     | Yes        | B 2 Closed Fist Operation?             | Yes  |

#### MUTCD Compliance

|     |                           |               |     |                           |               |
|-----|---------------------------|---------------|-----|---------------------------|---------------|
| Yes | B 1 Clear Xing Direction? | ClearlyMarked | Yes | B 2 Clear Xing Direction? | ClearlyMarked |
|     | B 1 Crossing Direction    | To SW         |     | B 2 Crossing Direction    | To SE         |
| Yes | B 1 DistanceTo XWalk (in) | 0.0           | No  | B 2 DistanceTo XWalk (in) | 64.0          |
| No  | B 1 DistanceTo Curb (in)  | 135.0         | No  | B 2 DistanceTo Curb (in)  | 120.0         |
| Yes | B 1 Diameter (in)         | 2.0           | Yes | B 2 Diameter (in)         | 2.0           |

#### APS Compliance

|                             |                                 |                             |                                 |
|-----------------------------|---------------------------------|-----------------------------|---------------------------------|
| Is Button 1 APS or Non-APS? | APS                             | Is Button 2 APS or Non-APS? | APS                             |
| Yes                         | B 1 VibroTact Arrow?            | Yes                         | B 2 VibroTact Arrow?            |
| Yes                         | B 1 VibroTact Parallel to Xing? | Yes                         | B 2 VibroTact Parallel to Xing? |
| Yes                         | B 1 VibroTact Contrast          | Yes                         | B 2 VibroTact Contrast          |
| Yes                         | B 1 Pilot Light?                | Yes                         | B 2 Pilot Light?                |
| Yes                         | B 1 Pilot Light Illumination?   | Yes                         | B 2 Pilot Light Illumination?   |
| Yes                         | B 1 Verbal Walk Cycle?          | Yes                         | B 2 Verbal Walk Cycle?          |
| Yes                         | B 1 Verbal Message Audible?     | Yes                         | B 2 Verbal Message Audible?     |
| Yes                         | B 1 Locator Tone?               | Yes                         | B 2 Locator Tone?               |
| No                          | B 1 Percussive Walk Cycle?      | Yes                         | B 2 Percussive Walk Cycle?      |
| Yes                         | B 1 Extended Press Feature?     | Yes                         | B 2 Extended Press Feature?     |
| Yes                         | B 1 Tone Audible Range?         | Yes                         | B 2 Tone Audible Range?         |