


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10013094	Main Street: N_GRAHAM_ST	Cross Street: FRANKLIN_AV	Location: W
ADA ID: 01444D5CF3D3	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Sidewalk Connection to Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

810.2.3, R302

CATS Stop ID: 17830
CATS Stop Description: **Graham St & Franklin Av**
CATS Route ID: 22
CATS Route Name: **Graham Street**

Total Cost: \$ 2750.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	70.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.4
Yes	Boarding Area XSlope %	0.7
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.9
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	1.1
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	97.0
N/A	Bench?	No
No	Protruding Objects?	Yes

