


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10032567	Main Street: N_GRAHAM_ST	Cross Street: W_10TH_ST	Location: N
ADA ID: 02005DADF1AF	Overall Compliance: No	Severity Score: 75	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Provide Sidewalk Connection to Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

810.2, 810.2.3, R302, R308.1.1

CATS Stop ID: 11350
CATS Stop Description: **Graham St & 10th St**
CATS Route ID: 22, 26
CATS Route Name: **Multiple**

Total Cost: \$ 3450.00

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	74.0
Yes	PAR 1 Slope %	0.4
Yes	PAR 1 XSlope %	0.2
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	74.0
Yes	PAR 2 Slope %	0.5
Yes	PAR 2 XSlope %	0.2
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	2.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	87.0
N/A	Bench?	No
No	Protruding Objects?	Yes

