


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                        |                               |                                 |             |
|------------------------|-------------------------------|---------------------------------|-------------|
| Intersection ID: 12953 | Main Street: HICKORY GROVE RD | Cross Street: MARTHA'S RIDGE DR | Location: N |
| ADA ID: 044BCEC88211   | Overall Compliance: No        | Severity Score: 60              |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.2, 810.2.3, 810.2.4, R302,  
R302.5, R302.6, R308.1.1.1,  
R308.1.1.2**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| No         | Boarding Area Width (in)        | 48.0  |
| Yes        | Boarding Area Length (in)       | 114.0 |
| No         | Boarding Area Slope %           | 5.6   |
| Yes        | Boarding Area XSlope %          | 3.1   |
| No         | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 60.0  |
| Yes        | PAR 1 Slope %                   | 3.8   |
| No         | PAR 1 XSlope %                  | 2.5   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| No         | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 60.0  |
| Yes        | PAR 2 Slope %                   | 2.7   |
| No         | PAR 2 XSlope %                  | 3.0   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 4.4   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 91.0  |
| N/A        | Bench?                          | No    |
| Yes        | Protruding Objects?             | No    |

CATS Stop ID: 11930

CATS Stop Description: Hickory Grove Rd & Martha's Ridge Dr

CATS Route ID: 222

CATS Route Name: Pence Road

Total Cost: \$ 2150.00

