


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 6503	Main Street: BEATTIES_FORD_RD	Cross Street: SLATER_RD	Location: W
ADA ID: 04A0625355F5	Overall Compliance: No	Severity Score: 70	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Provide Boarding Area. Provide Transit Stop Sign.

Surveyor Notes:

AREA UNDER CONSTRUCTION, SIGN ON GROUND. BUS STOP HAS BEEN REMOVED.

PROW/ADA:

703.5.1, 810.2, R308.1.1, R410.6

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	1.8
Yes	PAR 1 XSlope %	1.7
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
No	Transit Sign?	No
N/A	Transit Sign Height (in)	N/A
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 02840

CATS Stop Description: Beatties Ford Rd & Slater Rd

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 1200.00

