


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 44886	Main Street: BERRYHILL_RD	Cross Street: BORDER_DR	Location: W
ADA ID: 04CBC5F2CD2F	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Sidewalk To Boarding Area.
Remove & Replace Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 402.2, 810.2.4, 810.3, R302,
R308.1.1.2, R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	6.5
No	Boarding Area XSlope %	2.5
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	No
N/A	Road Slope %	2.1
N/A	Shelter	No
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	No
Yes	Clear Floor Space Width (in)	100.0
Yes	Clear Floor Space Length (in)	97.0
Yes	Clear Floor Space Slope %	0.4
No	Clear Floor Space XSlope %	2.4
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 03160

CATS Stop Description: **Berryhill Rd & Freedom Dr**

CATS Route ID: 34

CATS Route Name: **Freedom Drive**

Total Cost: \$ 1750.00

