


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 13002	Main Street: CENTRAL_AV	Cross Street: PIEDMONT_ST	Location: SW
ADA ID: 0528C225615E	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Provide Clear Floor Space.**

Surveyor Notes:

N/A

PROW/ADA:

810.2.4, 810.3, R308.1.1.2, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	97.0
No	Boarding Area Slope %	6.6
Yes	Boarding Area XSlope %	1.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
Yes	PAR 1 Slope %	1.2
Yes	PAR 1 XSlope %	1.0
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	1.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.9
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 04990

CATS Stop Description: Central Ave & Piedmont St

CATS Route ID: 17, 9

CATS Route Name: Multiple

Total Cost: \$ 1200.00

