


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                                         |                         |                                         |             |
|-----------------------------------------|-------------------------|-----------------------------------------|-------------|
| Intersection ID: 10012641               | Main Street: NORRIS_AV  | Cross Street: N/A                       | Location: S |
| ADA ID: 068522520260                    | Overall Compliance: N/A | Severity Score: 50                      |             |
| Codes/Mitigation Info/Possible Solution |                         | Field Measurements/Component Compliance |             |



Possible Solutions:

N/A

Surveyor Notes:

**CURB WIDTH 16.0 IN**

PROW/ADA:

N/A

CATS Stop ID: 45719

CATS Stop Description: Norris Ave & Grimes St

CATS Route ID: 3

CATS Route Name: The Plaza

Total Cost: \$0.00

| Compliance | Description                     | Data |
|------------|---------------------------------|------|
| N/A        | Boarding Area                   | Yes  |
| N/A        | Boarding Area Width (in)        | 60.0 |
| N/A        | Boarding Area Length (in)       | 54.0 |
| N/A        | Boarding Area Slope %           | 1.6  |
| N/A        | Boarding Area XSlope %          | 0.1  |
| N/A        | PAR 1 Exist?                    | Yes  |
| N/A        | PAR 1 Width (in)                | 38.0 |
| N/A        | PAR 1 Slope %                   | 0.1  |
| N/A        | PAR 1 XSlope %                  | 1.6  |
| N/A        | PAR 1 XSlope Location           | Perp |
| N/A        | PAR 2 Exist?                    | Yes  |
| N/A        | PAR 2 Width (in)                | 38.0 |
| N/A        | PAR 2 Slope %                   | 2.9  |
| N/A        | PAR 2 XSlope %                  | 1.4  |
| N/A        | PAR 2 XSlope Location           | Perp |
| N/A        | Boarding Area Connected to PAR? | Yes  |
| N/A        | Road Slope %                    | 2.2  |
| N/A        | Shelter                         | No   |
| N/A        | Clear Floor Space               | No   |
| N/A        | Clear Floor Space Shelter       | No   |
| N/A        | Clear Floor Space Width (in)    | N/A  |
| N/A        | Clear Floor Space Length (in)   | N/A  |
| N/A        | Clear Floor Space Slope %       | N/A  |
| N/A        | Clear Floor Space XSlope %      | N/A  |
| N/A        | Alcove Condition?               | No   |
| N/A        | Transit Sign?                   | Yes  |
| N/A        | Transit Sign Height (in)        | 93.5 |
| N/A        | Bench?                          | No   |
| N/A        | Protruding Objects?             | No   |

