


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10041770	Main Street: WILKINSON_BV	Cross Street: N/A	Location: NW
ADA ID: 098F55A24687	Overall Compliance: No	Severity Score: 25	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.2, 810.2.4, 810.3,
R308.1.1.1, R308.1.1.2, R404.1,
R404.2**

CATS Stop ID: **45419**

CATS Stop Description: **Wilkinson Blvd & Harlee Ave**

CATS Route ID: **5**

CATS Route Name: **Sprinter**

Total Cost: \$ **1250.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	175.0
No	Boarding Area Length (in)	76.0
No	Boarding Area Slope %	2.2
Yes	Boarding Area XSlope %	4.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	90.0
Yes	PAR 1 Slope %	2.3
Yes	PAR 1 XSlope %	2.0
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	4.8
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	55.0
Yes	Clear Floor Space Length (in)	60.0
Yes	Clear Floor Space Slope %	1.3
No	Clear Floor Space XSlope %	3.2
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	95.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

