


# Access Compliance Report

## Public Rights-of-Way

### (Transit Stops)

|                       |                                 |                              |             |
|-----------------------|---------------------------------|------------------------------|-------------|
| Intersection ID: 4428 | Main Street: LONG_CREEK_PARK_DR | Cross Street: STATESVILLE_RD | Location: W |
| ADA ID: 0A1C65B399CC  | Overall Compliance: No          | Severity Score: 50           |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Provide Sidewalk To Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, R302**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 119.0 |
| Yes        | Boarding Area Length (in)       | 119.0 |
| Yes        | Boarding Area Slope %           | 1.9   |
| Yes        | Boarding Area XSlope %          | 0.9   |
| No         | PAR 1 Exist?                    | No    |
| N/A        | PAR 1 Width (in)                | N/A   |
| N/A        | PAR 1 Slope %                   | N/A   |
| N/A        | PAR 1 XSlope %                  | N/A   |
| N/A        | PAR 1 XSlope Location           | N/A   |
| N/A        | PAR 2 Exist?                    | No    |
| N/A        | PAR 2 Width (in)                | N/A   |
| N/A        | PAR 2 Slope %                   | N/A   |
| N/A        | PAR 2 XSlope %                  | N/A   |
| N/A        | PAR 2 XSlope Location           | N/A   |
| N/A        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 1.2   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 88.0  |
| N/A        | Bench?                          | No    |
| Yes        | Protruding Objects?             | No    |

CATS Stop ID: 45842

CATS Stop Description: Statesville Rd & Long Creek Park Dr

CATS Route ID: 7

CATS Route Name: Beatties Ford

Total Cost: \$ 500.00

