


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10193	Main Street: N_GRAHAM_ST	Cross Street: WOLFBERRY_ST	Location: E
ADA ID: 0B555B85FAB8	Overall Compliance: No	Severity Score: 80	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Provide Boarding Area. Remove & Replace Sidewalk To Boarding Area. Adjust Transit Stop Sign Height.

Surveyor Notes:

N/A

PROW/ADA:

302.7, 402.2, 810.2, 810.2.3, R302, R302.5, R302.6, R308.1.1, R402.3

Compliance	Description	Data
No	Boarding Area	No
N/A	Boarding Area Width (in)	N/A
N/A	Boarding Area Length (in)	N/A
N/A	Boarding Area Slope %	N/A
N/A	Boarding Area XSlope %	N/A
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.5
No	PAR 1 XSlope %	5.5
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.3
No	PAR 2 XSlope %	4.6
N/A	PAR 2 XSlope Location	Perp
No	Boarding Area Connected to PAR?	No
N/A	Road Slope %	0.9
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
No	Transit Sign Height (in)	78.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 17760

CATS Stop Description: **Graham St & Wolfberry St**

CATS Route ID: 22

CATS Route Name: **Graham Street**

Total Cost: \$ 2300.00

