


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 1002389	Main Street: DAVID_TAYLOR_DR	Cross Street: N/A	Location: E
ADA ID: 0C4F913B51B0	Overall Compliance: No	Severity Score: 45	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance		
 DAVID_TAYLOR_DR	Possible Solutions:	Compliance	Description	Data
	Remove & Replace Boarding Area.	Yes	Boarding Area	Yes
	Remove & Replace Sidewalk To Boarding Area.	Yes	Boarding Area Width (in)	120.0
		Yes	Boarding Area Length (in)	132.0
		No	Boarding Area Slope %	3.6
		Yes	Boarding Area XSlope %	1.7
		No	PAR 1 Exist?	Yes
	Surveyor Notes:	Yes	PAR 1 Width (in)	60.0
	N/A	Yes	PAR 1 Slope %	2.0
		No	PAR 1 XSlope %	2.6
		N/A	PAR 1 XSlope Location	Perp
		No	PAR 2 Exist?	Yes
		Yes	PAR 2 Width (in)	60.0
		Yes	PAR 2 Slope %	1.4
	PROW/ADA:	No	PAR 2 XSlope %	2.8
	402.2, 810.2.3, 810.2.4, R302, R302.5, R302.6, R308.1.1.2	N/A	PAR 2 XSlope Location	Perp
		Yes	Boarding Area Connected to PAR?	Yes
		N/A	Road Slope %	2.8

CATS Stop ID: 44291

CATS Stop Description: David Taylor Dr & Andrew Carnegie Blvd

CATS Route ID: 54

CATS Route Name: URP

Total Cost: \$ 2150.00

