


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 1002286	Main Street: VAN_LANDINGHAM_RD	Cross Street: N/A	Location: SW
ADA ID: 0DB9EE4D8261	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.4, 810.3, R308.1.1.2,
R404.1, R404.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	1.4
No	Boarding Area XSlope %	4.5
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	50.0
Yes	PAR 1 Slope %	4.0
Yes	PAR 1 XSlope %	0.7
N/A	PAR 1 XSlope Location	Perp
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	4.3
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	52.0
Yes	Clear Floor Space Length (in)	70.0
Yes	Clear Floor Space Slope %	1.7
No	Clear Floor Space XSlope %	4.4
N/A	Alcove Condition?	Yes
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	91.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 14700

CATS Stop Description: Van LANDINGHAM Rd & John Kirk Dr

CATS Route ID: 29

CATS Route Name: UNCC / JW Clay

Total Cost: \$ 3250.00

