


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10025682	Main Street: EAST_BV	Cross Street: N/A	Location: NE
ADA ID: 1158EE4010C5	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 403.5.1, 810.2.3, R302, R302.3, R302.6

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	100.0
Yes	Boarding Area Slope %	1.6
Yes	Boarding Area XSlope %	1.3
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.5
No	PAR 1 Slope %	2.6
Yes	PAR 1 XSlope %	0.6
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
Yes	PAR 2 Slope %	0.5
No	PAR 2 XSlope %	3.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.0
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: 08820

CATS Stop Description: East Blvd & Kings Dr

CATS Route ID: 6

CATS Route Name: Kings Drive

Total Cost: \$ 1400.00

