


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                           |                            |                                     |             |
|---------------------------|----------------------------|-------------------------------------|-------------|
| Intersection ID: 10040577 | Main Street: W_ARROWOOD_RD | Cross Street: CRESCENT_EXECUTIVE_DR | Location: N |
| ADA ID: 14BB7EEC6570      | Overall Compliance: No     | Severity Score: 55                  |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Remove & Replace Boarding Area.  
Provide Sidewalk Connection to  
Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**810.2.3, 810.2.4, R302, R308.1.1.2**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 121.5 |
| Yes        | Boarding Area Length (in)       | 108.0 |
| No         | Boarding Area Slope %           | 3.5   |
| Yes        | Boarding Area XSlope %          | 0.7   |
| Yes        | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 60.0  |
| Yes        | PAR 1 Slope %                   | 1.6   |
| Yes        | PAR 1 XSlope %                  | 0.3   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| Yes        | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 60.0  |
| Yes        | PAR 2 Slope %                   | 0.5   |
| Yes        | PAR 2 XSlope %                  | 1.7   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| No         | Boarding Area Connected to PAR? | No    |
| N/A        | Road Slope %                    | 1.4   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 94.0  |
| N/A        | Bench?                          | No    |
| Yes        | Protruding Objects?             | No    |

CATS Stop ID: 01030

CATS Stop Description: Arrowood Rd & Crescent Executive Dr

CATS Route ID: 56

CATS Route Name: Arrowood

Total Cost: \$ 1500.00

