


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10011596	Main Street: STATESVILLE_RD	Cross Street: N/A	Location: E
ADA ID: 15002B774A05	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Provide Sidewalk To Boarding Area.
Provide Clear Floor Space.**

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.3, R302, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	64.0
Yes	Boarding Area Length (in)	96.0
Yes	Boarding Area Slope %	0.8
Yes	Boarding Area XSlope %	1.2
No	PAR 1 Exist?	No
N/A	PAR 1 Width (in)	N/A
N/A	PAR 1 Slope %	N/A
N/A	PAR 1 XSlope %	N/A
N/A	PAR 1 XSlope Location	N/A
N/A	PAR 2 Exist?	No
N/A	PAR 2 Width (in)	N/A
N/A	PAR 2 Slope %	N/A
N/A	PAR 2 XSlope %	N/A
N/A	PAR 2 XSlope Location	N/A
N/A	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.4
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	86.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: **46376**

CATS Stop Description: **Statesville Rd & Lakeview Rd**

CATS Route ID: **7**

CATS Route Name: **Beatties Ford**

Total Cost: \$ **950.00**

