


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10025513	Main Street: E_MOREHEAD_ST	Cross Street: N/A	Location: W
ADA ID: 182C883649DF	Overall Compliance: No	Severity Score: 25	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

**305.2, 810.2.4, 810.3, R308.1.1.2,
R404.1, R404.2**

CATS Stop ID: **07810**

CATS Stop Description: **Morehead St & Kenilworth Ave**

CATS Route ID: **20, 6**

CATS Route Name: **Multiple**

Total Cost: \$ **3250.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	108.0
No	Boarding Area Slope %	4.3
Yes	Boarding Area XSlope %	0.1
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	72.0
Yes	PAR 1 Slope %	0.3
Yes	PAR 1 XSlope %	0.5
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	72.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	1.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.1
N/A	Shelter	Yes
No	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	46.0
Yes	Clear Floor Space Length (in)	48.0
No	Clear Floor Space Slope %	5.3
No	Clear Floor Space XSlope %	2.3
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	88.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

