


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10037033	Main Street: S_TRYON_ST	Cross Street: PARKAIRE_LN	Location: N
ADA ID: 1A393B9FFA02	Overall Compliance: No	Severity Score: 50	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Boarding Area.

Surveyor Notes:

N/A

PROW/ADA:

**810.2.2, 810.2.4, R308.1.1.1,
R308.1.1.2**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	124.0
No	Boarding Area Length (in)	60.0
No	Boarding Area Slope %	7.8
Yes	Boarding Area XSlope %	0.2
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	0.7
Yes	PAR 1 XSlope %	0.1
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.1
Yes	PAR 2 XSlope %	0.8
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	0.9
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	93.0
N/A	Bench?	No
Yes	Protruding Objects?	No

CATS Stop ID: **45100**

CATS Stop Description: **Tryon St & Kingman Dr**

CATS Route ID: **16, 41x**

CATS Route Name: **Multiple**

Total Cost: \$ **750.00**

