


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 16724	Main Street: CHARLOTTE_PARK_DR	Cross Street: PRESSLEY_RD	Location: S
ADA ID: 1E06CD52C189	Overall Compliance: No	Severity Score: 15	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 403.5.1, 810.2.2, R302, R302.3,
R308.1.1.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
No	Boarding Area Length (in)	80.0
Yes	Boarding Area Slope %	0.3
Yes	Boarding Area XSlope %	1.2
No	PAR 1 Exist?	Yes
No	PAR 1 Width (in)	47.0
Yes	PAR 1 Slope %	1.2
Yes	PAR 1 XSlope %	0.3
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
No	PAR 2 Width (in)	47.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	1.3
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.5
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	48.0
Yes	Clear Floor Space Length (in)	48.0
Yes	Clear Floor Space Slope %	1.9
Yes	Clear Floor Space XSlope %	1.5
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

CATS Stop ID: 22000

CATS Stop Description: Pressley Rd & Charlotte Park Dr

CATS Route ID: 12

CATS Route Name: South Boulevard

Total Cost: \$ 2150.00

