


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 15816	Main Street: BARAWAY_DR	Cross Street: E_W_T_HARRIS_BV	Location: NE
ADA ID: 1F3FE30FE412	Overall Compliance: No	Severity Score: 20	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove or Relocate Protruding
Objects/Obstructions.**

Surveyor Notes:

N/A

PROW/ADA:

810.2.4, R308.1.1.2

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	5.2
Yes	Boarding Area XSlope %	2.0
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
Yes	PAR 1 Slope %	2.6
Yes	PAR 1 XSlope %	1.4
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
Yes	PAR 2 Slope %	0.9
Yes	PAR 2 XSlope %	0.1
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.4
N/A	Shelter	Yes
Yes	Clear Floor Space	Yes
N/A	Clear Floor Space Shelter	Yes
Yes	Clear Floor Space Width (in)	65.0
Yes	Clear Floor Space Length (in)	56.0
Yes	Clear Floor Space Slope %	0.7
Yes	Clear Floor Space XSlope %	0.9
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	90.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 45759

CATS Stop Description: WT Harris Blvd & Snow Ln

CATS Route ID: 221, 3

CATS Route Name: Multiple

Total Cost: \$ 2750.00

