


# Access Compliance Report Public Rights-of-Way (Transit Stops)

|                           |                               |                    |             |
|---------------------------|-------------------------------|--------------------|-------------|
| Intersection ID: 10033477 | Main Street: OLD_PINEVILLE_RD | Cross Street: N/A  | Location: E |
| ADA ID: 1FAE6EC7B7A3      | Overall Compliance: No        | Severity Score: 50 |             |

| Codes/Mitigation Info/Possible Solution | Field Measurements/Component Compliance |
|-----------------------------------------|-----------------------------------------|
|-----------------------------------------|-----------------------------------------|



Possible Solutions:

**Remove & Replace Boarding Area.  
Remove & Replace Sidewalk To  
Boarding Area.**

Surveyor Notes:

**N/A**

PROW/ADA:

**402.2, 810.2.3, 810.2.4, R302, R302.5,  
R302.6, R308.1.1.2**

| Compliance | Description                     | Data  |
|------------|---------------------------------|-------|
| Yes        | Boarding Area                   | Yes   |
| Yes        | Boarding Area Width (in)        | 120.0 |
| Yes        | Boarding Area Length (in)       | 148.0 |
| No         | Boarding Area Slope %           | 2.1   |
| No         | Boarding Area XSlope %          | 2.3   |
| No         | PAR 1 Exist?                    | Yes   |
| Yes        | PAR 1 Width (in)                | 68.0  |
| No         | PAR 1 Slope %                   | 2.3   |
| No         | PAR 1 XSlope %                  | 2.1   |
| N/A        | PAR 1 XSlope Location           | Perp  |
| No         | PAR 2 Exist?                    | Yes   |
| Yes        | PAR 2 Width (in)                | 68.0  |
| No         | PAR 2 Slope %                   | 2.5   |
| Yes        | PAR 2 XSlope %                  | 1.9   |
| N/A        | PAR 2 XSlope Location           | Perp  |
| Yes        | Boarding Area Connected to PAR? | Yes   |
| N/A        | Road Slope %                    | 2.2   |
| N/A        | Shelter                         | No    |
| N/A        | Clear Floor Space               | No    |
| N/A        | Clear Floor Space Shelter       | No    |
| N/A        | Clear Floor Space Width (in)    | N/A   |
| N/A        | Clear Floor Space Length (in)   | N/A   |
| N/A        | Clear Floor Space Slope %       | N/A   |
| N/A        | Clear Floor Space XSlope %      | N/A   |
| N/A        | Alcove Condition?               | No    |
| Yes        | Transit Sign?                   | Yes   |
| Yes        | Transit Sign Height (in)        | 91.5  |
| N/A        | Bench?                          | No    |
| Yes        | Protruding Objects?             | No    |

CATS Stop ID: **46035**

CATS Stop Description: **Archdale Station**

CATS Route ID: **57**

CATS Route Name: **Archdale**

Total Cost: \$ **2150.00**

