


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10011250	Main Street: THOMAS_AV	Cross Street: CENTRAL AVE	Location: S
ADA ID: 21393AE6EE33	Overall Compliance: No	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Provide Clear Floor
Space. Remove or Relocate
Protruding Objects/Obstructions.**

Surveyor Notes:

**MATERIAL PAVERS, MEASURED
48.0 FOR WIDTH PAST 96.0 FOR
BOARDING LENGTH**

PROW/ADA:

**402.2, 810.2.3, 810.2.4, 810.3, R302,
R302.5, R302.6, R308.1.1.2, R404.1**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	96.0
No	Boarding Area Slope %	2.1
Yes	Boarding Area XSlope %	1.2
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	48.0
No	PAR 1 Slope %	2.6
No	PAR 1 XSlope %	4.9
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	48.0
No	PAR 2 Slope %	2.3
No	PAR 2 XSlope %	3.6
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.7
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	89.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 05170

CATS Stop Description: Central Ave & Thomas Ave

CATS Route ID: 17, 9

CATS Route Name: Multiple

Total Cost: \$ 4600.00

