


Access Compliance Report

Public Rights-of-Way

(Transit Stops)

Intersection ID: 10036989	Main Street: S_TRYON_ST	Cross Street: E_JOHN_BELK_RA	Location: W
ADA ID: 22176CF27B8B	Overall Compliance: N/A	Severity Score: 45	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

CATS Stop ID: 25800

CATS Stop Description: Tryon St & Morehead St

CATS Route ID: 16

CATS Route Name: South Tryon

Total Cost: \$0.00

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	60.0
Yes	Boarding Area Length (in)	108.0
Yes	Boarding Area Slope %	0.9
Yes	Boarding Area XSlope %	2.6
Yes	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	108.0
Yes	PAR 1 Slope %	2.6
Yes	PAR 1 XSlope %	0.9
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	92.0
Yes	PAR 2 Slope %	2.6
Yes	PAR 2 XSlope %	1.0
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.4
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	92.0
N/A	Bench?	No
Yes	Protruding Objects?	No

