


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10040499	Main Street: W_4TH_ST_EXT	Cross Street: S_SYCAMORE_ST	Location: N
ADA ID: 229BF3C2339D	Overall Compliance: No	Severity Score: 55	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Boarding Area.
Remove & Replace Sidewalk To
Boarding Area. Provide Clear Floor
Space.**

Surveyor Notes:

N/A

PROW/ADA:

**402.2, 810.2.3, 810.2.4, 810.3, R302,
R302.5, R302.6, R308.1.1.2, R404.1**

CATS Stop ID: **33280**
CATS Stop Description: **4th St Ext & Sycamore St**
CATS Route ID: **34, 8**
CATS Route Name: **Multiple**

Total Cost: \$ **2600.00**

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	115.0
Yes	Boarding Area Length (in)	100.0
No	Boarding Area Slope %	4.2
Yes	Boarding Area XSlope %	2.8
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	60.0
No	PAR 1 Slope %	3.6
Yes	PAR 1 XSlope %	1.1
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	60.0
No	PAR 2 Slope %	3.8
Yes	PAR 2 XSlope %	0.4
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	3.5
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
Yes	Protruding Objects?	No

