


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10025611	Main Street: E_WOODLAWN_RD	Cross Street: N/A	Location: NE
ADA ID: 2518213A9B82	Overall Compliance: No	Severity Score: 45	

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance
---	---



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Provide Clear Floor Space. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, 810.3, R302, R302.5, R302.6, R404.1

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	180.0
Yes	Boarding Area Length (in)	113.0
Yes	Boarding Area Slope %	0.6
Yes	Boarding Area XSlope %	3.8
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	95.0
No	PAR 1 Slope %	4.7
Yes	PAR 1 XSlope %	2.0
N/A	PAR 1 XSlope Location	Perp
No	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	95.0
No	PAR 2 Slope %	4.6
No	PAR 2 XSlope %	2.2
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	4.5
N/A	Shelter	No
No	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	96.0
N/A	Bench?	Yes
No	Protruding Objects?	Yes

CATS Stop ID: 35830

CATS Stop Description: Woodlawn Rd & Park Rd

CATS Route ID: 30

CATS Route Name: Woodlawn Crosstown

Total Cost: \$ 3850.00

