


Access Compliance Report Public Rights-of-Way (Transit Stops)

Intersection ID: 10012482	Main Street: STATESVILLE_RD	Cross Street: WINSLOW_DR	Location: W
ADA ID: 25C66B4BB79F	Overall Compliance: No	Severity Score: 40	
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Sidewalk To Boarding Area. Remove or Relocate Protruding Objects/Obstructions.

Surveyor Notes:

N/A

PROW/ADA:

402.2, 810.2.3, R302, R302.6

Compliance	Description	Data
Yes	Boarding Area	Yes
Yes	Boarding Area Width (in)	119.5
Yes	Boarding Area Length (in)	173.0
Yes	Boarding Area Slope %	1.0
Yes	Boarding Area XSlope %	1.9
No	PAR 1 Exist?	Yes
Yes	PAR 1 Width (in)	119.0
No	PAR 1 Slope %	2.2
Yes	PAR 1 XSlope %	0.7
N/A	PAR 1 XSlope Location	Perp
Yes	PAR 2 Exist?	Yes
Yes	PAR 2 Width (in)	72.0
Yes	PAR 2 Slope %	0.8
Yes	PAR 2 XSlope %	1.5
N/A	PAR 2 XSlope Location	Perp
Yes	Boarding Area Connected to PAR?	Yes
N/A	Road Slope %	1.3
N/A	Shelter	No
N/A	Clear Floor Space	No
N/A	Clear Floor Space Shelter	No
N/A	Clear Floor Space Width (in)	N/A
N/A	Clear Floor Space Length (in)	N/A
N/A	Clear Floor Space Slope %	N/A
N/A	Clear Floor Space XSlope %	N/A
N/A	Alcove Condition?	No
Yes	Transit Sign?	Yes
Yes	Transit Sign Height (in)	94.5
N/A	Bench?	No
No	Protruding Objects?	Yes

CATS Stop ID: 59770

CATS Stop Description: Statesville Rd & Oakwood Dr

CATS Route ID: 21

CATS Route Name: Statesville Ave

Total Cost: \$ 2700.00

